

ВЕДОМОСТЬ
учета потребления теплоты с 22.09.2016 по 25.10.2016

Адрес ул. Чкаловского 38

Лицевой счет: 7560657

Договорные нагрузки: отопление:

ГВС:

вентиляция:

Счетчик СВТУ-10М № 17565 Вар. 5

Мин. дельта t=2,5 °C

РУ-50 (0,70 - 70 куб.м/ч); РУ-50 (0,70 - 70 куб.м/ч)

302

Дата	Траб ч	Температура, °C			Расход, т			Тепло W, ГКал	Тош, ч 1 / 2	Температуры, °C					Давление P1 / P2 кгс/см2	Типы ошибок
		tn	to	txв	M1	M2	dM2			t2	t3	t4	t5	t6		
22.09.2016	24,00	63,0	52,3	---	163,121	167,258	-4,137	1,741	0,0/0,0	52,3	---	---	---	---	6,00/4,00	
23.09.2016	24,00	62,0	51,5	---	162,285	166,354	-4,068	1,706	0,0/0,0	51,5	---	---	---	---	6,00/4,00	
24.09.2016	24,00	62,7	51,2	---	162,805	166,898	-4,094	1,866	0,0/0,0	51,2	---	---	---	---	6,00/4,00	
25.09.2016	24,00	62,6	50,3	---	162,432	166,402	-3,971	2,001	0,0/0,0	50,3	---	---	---	---	6,00/4,00	
26.09.2016	24,00	62,5	51,7	---	162,145	166,053	-3,908	1,753	0,0/0,0	51,7	---	---	---	---	6,00/4,00	
27.09.2016	24,00	63,1	51,8	---	161,914	165,869	-3,955	1,840	0,0/0,0	51,8	---	---	---	---	6,00/4,00	
28.09.2016	24,00	61,9	50,8	---	161,645	165,682	-4,037	1,812	0,0/0,0	50,8	---	---	---	---	6,00/4,00	
29.09.2016	24,00	61,7	50,9	---	161,596	165,680	-4,084	1,742	0,0/0,0	50,9	---	---	---	---	6,00/4,00	
30.09.2016	24,00	60,0	49,4	---	161,934	165,939	-4,006	1,720	0,0/0,0	49,4	---	---	---	---	6,00/4,00	
01.10.2016	24,00	63,4	52,4	---	161,918	166,313	-4,395	1,780	0,0/0,0	52,4	---	---	---	---	6,00/4,00	
02.10.2016	24,00	63,4	52,2	---	162,045	166,434	-4,389	1,830	0,0/0,0	52,2	---	---	---	---	6,00/4,00	
03.10.2016	24,00	64,5	53,3	---	162,098	166,537	-4,439	1,808	0,0/0,0	53,3	---	---	---	---	6,00/4,00	
04.10.2016	24,00	64,0	53,0	---	161,588	166,021	-4,434	1,773	0,0/0,0	53,0	---	---	---	---	6,00/4,00	
05.10.2016	24,00	64,5	53,4	---	162,008	166,498	-4,490	1,807	0,0/0,0	53,4	---	---	---	---	6,00/4,00	
06.10.2016	24,00	64,9	53,8	---	161,992	166,469	-4,477	1,815	0,0/0,0	53,8	---	---	---	---	6,00/4,00	
07.10.2016	24,00	65,0	53,0	---	162,461	166,916	-4,455	1,954	0,0/0,0	53,0	---	---	---	---	6,00/4,00	
08.10.2016	24,00	65,6	53,3	---	162,316	166,727	-4,410	2,002	0,0/0,0	53,3	---	---	---	---	6,00/4,00	
09.10.2016	24,00	65,3	52,2	---	161,703	166,088	-4,385	2,114	0,0/0,0	52,2	---	---	---	---	6,00/4,00	
10.10.2016	24,00	65,9	53,2	---	161,389	165,736	-4,348	2,063	0,0/0,0	53,2	---	---	---	---	6,00/4,00	
11.10.2016	24,00	69,1	55,5	---	161,379	165,896	-4,518	2,189	0,0/0,0	55,5	---	---	---	---	6,00/4,00	
12.10.2016	24,00	68,2	54,7	---	159,365	163,734	-4,369	2,155	0,0/0,0	54,7	---	---	---	---	6,00/4,00	
13.10.2016	24,00	64,4	51,7	---	156,158	160,543	-4,385	1,984	0,0/0,0	51,7	---	---	---	---	6,00/4,00	
14.10.2016	24,00	62,5	49,6	---	156,928	161,080	-4,152	2,022	0,0/0,0	49,6	---	---	---	---	6,00/4,00	
15.10.2016	24,00	63,3	50,1	---	161,229	165,391	-4,162	2,138	0,0/0,0	50,1	---	---	---	---	6,00/4,00	
16.10.2016	24,00	62,8	48,8	---	161,512	165,350	-3,838	2,262	0,0/0,0	48,8	---	---	---	---	6,00/4,00	
17.10.2016	24,00	62,5	46,2	---	151,343	155,404	-4,061	2,460	0,0/0,0	46,2	---	---	---	---	6,00/4,00	C
18.10.2016	24,00	62,6	43,5	---	378,184	391,941	-13,758	7,203	0,0/0,0	43,5	---	---	---	---	6,00/4,00	
19.10.2016	24,00	62,7	43,6	---	379,750	393,840	-14,090	7,252	0,0/0,0	43,6	---	---	---	---	6,00/4,00	
20.10.2016	24,00	63,0	43,8	---	394,734	409,457	-14,723	7,557	0,0/0,0	43,8	---	---	---	---	6,00/4,00	
21.10.2016	24,00	63,0	44,3	---	404,082	419,445	-15,363	7,548	0,0/0,0	44,3	---	---	---	---	6,00/4,00	
22.10.2016	24,00	63,0	44,2	---	389,328	404,117	-14,789	7,335	0,0/0,0	44,2	---	---	---	---	6,00/4,00	
23.10.2016	24,00	63,1	43,6	---	407,492	423,008	-15,516	7,936	0,0/0,0	43,6	---	---	---	---	6,00/4,00	
24.10.2016	24,00	63,1	44,2	---	385,648	400,250	-14,602	7,279	0,0/0,0	44,2	---	---	---	---	6,00/4,00	
25.10.2016	24,00	62,9	44,3	---	387,188	402,055	-14,867	7,200	0,0/0,0	44,3	---	---	---	---	6,00/4,00	
816,00		63,4	48,4	---	7313,712	7541,384	-227,672	109,649	0,0/0,0	48,4	---	---	---	---	6,00/4,00	C

159,31 Гкал

Коминский М.В.

27-10-16.

[Подпись]

II

13

ВЕДОМОСТЬ

учета потребления теплоты с 26.10.2016 по 28.11.2016

0555, Уричевка 38

Адрес

Уричевка, 38 (2 ввг)

Лицевой счет:

7560657

Договорные нагрузки: отопление:

ГВС:

вентиляция:

Счетчик СВТУ-10М № 17565 Вер. 5

Мин. дельта t=2,5 °C

РУ-50 (0,70 - 70 куб.м/ч); РУ-50 (0,70 - 70 куб.м/ч)

Дата	Траб ч	Температура, °C			Расход, т			Тепло W, ГКал	Тощ, ч 1/2	Температура, °C						Давление P1/P2 кгс/см2	Типы ошибок
		tn	to	txв	M1	M2	dM2			t2	t3	t4	t5	t6			
26.10.2016	24,00	62,8	43,6	---	338,797	351,344	-12,547	6,509	0,0/0,0	43,6	---	---	---	---	---	6,00/4,00	
27.10.2016	24,00	64,0	44,5	---	331,281	343,773	-12,492	6,470	0,0/0,0	44,5	---	---	---	---	---	6,00/4,00	
28.10.2016	24,00	65,0	49,0	---	419,512	436,289	-16,777	6,702	0,0/0,0	49,0	---	---	---	---	---	6,00/4,00	
29.10.2016	24,00	64,9	51,9	---	562,727	586,930	-24,203	7,365	0,0/0,0	51,9	---	---	---	---	---	6,00/4,00	
30.10.2016	24,00	65,2	52,0	---	580,813	605,914	-25,102	7,668	0,0/0,0	52,0	---	---	---	---	---	6,00/4,00	
31.10.2016	24,00	65,0	51,9	---	555,188	579,172	-23,984	7,276	0,0/0,0	51,9	---	---	---	---	---	6,00/4,00	
01.11.2016	24,00	65,1	51,3	---	585,523	610,844	-25,320	8,094	0,0/0,0	51,3	---	---	---	---	---	6,00/4,00	
02.11.2016	24,00	65,7	51,6	---	557,727	581,867	-24,141	7,922	0,0/0,0	51,6	---	---	---	---	---	6,00/4,00	
03.11.2016	24,00	66,9	52,7	---	482,445	503,258	-20,813	6,870	0,0/0,0	52,7	---	---	---	---	---	6,00/4,00	
04.11.2016	24,00	66,9	52,4	---	492,691	514,297	-21,406	7,155	0,0/0,0	52,4	---	---	---	---	---	6,00/4,00	
05.11.2016	24,00	66,9	52,1	---	535,766	559,039	-23,273	7,923	0,0/0,0	52,1	---	---	---	---	---	6,00/4,00	
06.11.2016	24,00	64,9	50,8	---	506,133	527,852	-21,719	7,133	0,0/0,0	50,8	---	---	---	---	---	6,00/4,00	
07.11.2016	24,00	63,5	50,7	---	458,930	478,695	-19,766	5,869	0,0/0,0	50,7	---	---	---	---	---	6,00/4,00	
08.11.2016	24,00	63,0	49,7	---	559,555	583,641	-24,086	7,439	0,0/0,0	49,7	---	---	---	---	---	6,00/4,00	
09.11.2016	24,00	64,6	50,6	---	546,609	569,922	-23,313	7,628	0,0/0,0	50,6	---	---	---	---	---	6,00/4,00	
10.11.2016	24,00	65,7	51,8	---	507,484	529,273	-21,789	7,075	0,0/0,0	51,8	---	---	---	---	---	6,00/4,00	
11.11.2016	24,00	66,0	51,7	---	535,523	558,516	-22,992	7,707	0,0/0,0	51,7	---	---	---	---	---	6,00/4,00	
12.11.2016	24,00	66,6	51,8	---	515,203	537,328	-22,125	7,620	0,0/0,0	51,8	---	---	---	---	---	6,00/4,00	
13.11.2016	24,00	67,4	51,9	---	597,078	622,445	-25,367	9,297	0,0/0,0	51,9	---	---	---	---	---	6,00/4,00	
14.11.2016	24,00	68,0	52,6	---	614,008	640,328	-26,320	9,458	0,0/0,0	52,6	---	---	---	---	---	6,00/4,00	
15.11.2016	24,00	68,6	53,0	---	639,016	666,555	-27,539	9,977	0,0/0,0	53,0	---	---	---	---	---	6,00/4,00	
16.11.2016	24,00	69,9	53,7	---	646,461	674,320	-27,859	10,437	0,0/0,0	53,7	---	---	---	---	---	6,00/4,00	
17.11.2016	24,00	69,4	53,5	---	610,938	637,313	-26,375	9,713	0,0/0,0	53,5	---	---	---	---	---	6,00/4,00	
18.11.2016	24,00	67,8	52,7	---	500,453	521,969	-21,516	7,561	0,0/0,0	52,7	---	---	---	---	---	6,00/4,00	
19.11.2016	24,00	67,0	51,7	---	512,742	534,711	-21,969	7,874	0,0/0,0	51,7	---	---	---	---	---	6,00/4,00	
20.11.2016	24,00	66,8	50,6	---	524,445	546,961	-22,516	8,505	0,0/0,0	50,6	---	---	---	---	---	6,00/4,00	
21.11.2016	24,00	66,9	51,5	---	567,930	592,313	-24,383	8,717	0,0/0,0	51,5	---	---	---	---	---	6,00/4,00	
22.11.2016	24,00	67,3	52,0	---	625,141	651,828	-26,688	9,619	0,0/0,0	52,0	---	---	---	---	---	6,00/4,00	
23.11.2016	24,00	67,9	52,3	---	588,695	613,852	-25,156	9,233	0,0/0,0	52,3	---	---	---	---	---	6,00/4,00	
24.11.2016	24,00	68,0	52,2	---	571,445	595,344	-24,398	9,067	0,0/0,0	52,2	---	---	---	---	---	6,00/4,00	
25.11.2016	24,00	67,8	52,2	---	528,016	550,586	-22,570	8,256	0,0/0,0	52,2	---	---	---	---	---	6,00/4,00	
26.11.2016	24,00	68,0	52,4	---	514,375	536,508	-22,133	8,071	0,0/0,0	52,4	---	---	---	---	---	6,00/4,00	
27.11.2016	24,00	67,9	52,1	---	487,109	507,914	-20,805	7,729	0,0/0,0	52,1	---	---	---	---	---	6,00/4,00	
28.11.2016	13,00	67,7	52,7	---	278,398	290,328	-11,930	4,183	0,0/0,0	52,7	---	---	---	---	---	6,00/4,00	
806,00		66,6	51,6	---	17878,35	18541,72	-763,371	268,122	0,0/0,0	51,6	---	---	---	---	---	6,00/4,00	

УБ

ΔG - 4,3%

 $V_2 \rightarrow V_1$

II

2,9

Типы ошибок:

A - системные ошибки; B - ошибки измерения температуры; C - ошибки измерения расхода; D - ошибки измерения давления; E - ошибки вычисления тепла